

181 US Hwy 46 Mine Hill, NJ 07830 (908) 654-8068 (800) 783-0567 Fax 908-654-8069

Lead-Based Paint Evaluation Report Inspection

Performed At:

439 Victory Ave Unit:Primary Primary Pohatcong Township, NJ 08865

Performed For:

Karen Campo 633 Bensel Dr Landing, NJ 07850

Prepared By:

LEW Environmental Services, LLC. 181 US Hwy 46 Mine Hill, NJ 07803 Phone (908) 654-8068 Fax (908) 654-8069 Inspection Date: 06/17/24 Order Number: 51876

Table Of Contents

Contact Information	3
Executive Summary	4
Components with Lead Based Paint	4
Regulatory Requirements	5
Required Disclosure	5
Required Training for Workers	5
Controlling Lead-Based Paint	5
Abatement for Lead-Based Paint Free Certification	6
Component Removal	6
Paint Stripping	6
Procedures & Methodology	6
Location Conventions	6
Paint Testing	6
X-Ray Fluorescence	6
Calibration Check Readings	7

Appendices

Appendix A - Floor Plan

Appendix B - Lead-Based Paint Evaluation Report

Contact Information

Site

Street Address	439 Victory Ave Unit Primary Pohatcong Township, NJ 08865
----------------	--------------------------------------------------------------

Property Owner

Name	Karen Campo
Street Address	633 Bensel Dr Landing, NJ 07850
Phone Number	973-479-6926

Lead-Based Paint Risk Assesor

Name	Neheru Singh
Certification Number	027180
Instrumentation	Viken Pb200i/e
Signature	Jula I
Date	06/25/2024

Firm

Organization:	LEW Environmental Services, LLC.
Certification #:	NJDCA 00015
Sreet:	181 US Hwy 46
City, State & Zip:	Mine Hill, NJ 07803
Phone Number:	908-654-8068
Web Address:	lewenvironmental.com



Executive Summary

For 439 Victory Ave Unit Primary Pohatcong Township, NJ 08865 06/25/2024

On 06/17/24, Neheru Singh of LEW Environmental Services, LLC (NJDCA 00015 E) performed a lead-based paint inspection at 439 Victory Ave Unit Primary . The lead-based paint inspection sampling protocol that was applied follows "Inspections in Single-Family Housing" Chapter 7 of the HUD Guidelines (2012 revision) and the protocol as referenced in USEPA 40 CFR Part 745.227(b). See Appendix B Lead Paint Inspection Report for the complete set of X-Ray Fluorescence data.

The tables below indicate the location of the lead-based paint found. Each positive reading applies to all similar components in the same room equivalent (room, hall, stairwell, building exterior, etc.) For a lead-based paint free certification, the lead must be stripped or the leaded component replaced and confirmation achieved. Enclosure and encapsulation are not acceptable methods for a lead-based paint free certification. If no lead-based paint was identified, the table will list "None" and the dwelling unit is considered lead-based paint free.

Components With Lead Based Paint

Room Equivalent	Component	Substrate	Value(mg/cm ²)
Basement Room 2	Door Jamb	Wood	5.2
Basement Room 2	Screen Door	Wood	1.3

EPA 40 CFR 745.227(h) states lead-based paint is present on any surface that is tested and found to contain lead equal to or in excess of 1.0 milligrams per square centimeter or equal to or in excess of 0.5% by weight. Local thresholds may be lower than this Federal standard.

Regulatory Requirements

Required Disclosure

A summary of this lead-based paint evaluation report must be provided to new lessees (tenants). A complete copy of this report must be provided to purchasers and owners of this property and it must be made available to new tenants under federal law (24 CFR PART 35 AND 40 CFR PART 745) before they become obligated under a lease or sales contract. Landlords (lessors) and sellers are also required to distribute an educational pamphlet approved by the U.S. Environmental Protection Agency and include standard warning language in their leases or sales contracts to ensure that parents have the information they need to protect their children from lead-based paint hazards."

Should the recipient of this report receive federal subsidy they are responsible to comply with all requirements of 24 CFR Part 35 Requirements for the Notification, Evaluation and Reduction of Lead-Based Paint Hazards in Federally Owned Residential Property and Housing Receiving Federal Assistance; Final Rule which, are applicable to the type of program they are participating in and the dollar amount of subsidy being received. If this property or any of its tenants receives financial federal assistance, the results of the evaluation or hazard reduction activities must be provided by the designated party (client) to the owner of the referenced property and the occupants within 15 calendar days of the date when the designated party receives this report, or makes the presumption that lead-based paint hazards do exist.

Required Training for Workers

Should the lead-based paint and lead hazard reduction activities be part of a program which receives federal subsidy or a New Jersey multifamily building, all persons performing "Interim Controls" or "Standard Treatments" must be trained in accordance with 29 CFR 1926.59 and be supervised by an individual who successfully completed one of the following courses:

- 1. A lead-based paint abatement supervisors course accredited in accordance with 40 CFR 745.225
- 2. A lead-based paint abatement worker course accredited in accordance with 40 CFR 745.225
- 3. The lead-based paint Maintenance Training Program, "Work Smart, Work Wet, and Work Clean to Work Lead Safe", prepared by the National Environmental Training Association for EPA and HUD
- 4. "The Remodeler's and Renovator's Lead-Based Paint Training Program," prepared by HUD and the National Association of the Remodeling Industry
- 5. Another course approved by HUD for this purpose after consultation with EPA.

In accordance with Section 35.1340 all Lead-Based Paint and Lead Hazard reduction activities, which are not exempt (see regulations) require Lead Dust Wipe Clearance testing by a 1) certified lead inspector, 2) certified risk assessor or 3) a dust wipe sampling technician whose work is reviewed by a certified risk assessor.

If a renovation at the property is to occur, all work should comply with 40 CFR 745 Subpart E-Residential Property Renovation.

Controlling Lead-Based Paint

There are different options available for controlling lead-based paint. Each option has its own associated costs and benefits both short and long term. In most cases, a combination of the options can be implemented to reduce the possibility of lead contamination. LEW Environmental Services,

LLC. strongly suggests that each option is thoroughly contemplated before beginning any activity.

Components that are found to be positive for lead-based paint should be checked for deterioration. Lead-based paint in deteriorated condition is considered a paint-lead hazard. Those components should be address as soon as possible using lead safe work practices at a minimum. However, if any components are found to test positive for lead based paint, they should be considered for future component removal or paint stripping.

Abatement for Lead-Based Paint Free Certification

Component Removal

Component removal is a permanent solution to the issue of potential exposure of lead. It requires taking the old lead-based painted component out and replacing it with a new non-lead painted component. The cost associated with this option depends mostly on the cost of the replacement component. Since labor is most often the more costly aspect of controlling lead issues, many owners choose component removal over more labor intensive methods. Components often chosen for removal are wood trim, windows, most doors, and exterior railings. Plaster and drywall ceilings and walls, fire rated doors, and wood porch components should also be considered.

Paint Stripping

Paint stripping is a permanent solution to the issue of potential exposure of lead. The paint can be removed either in-place or by an off-site processing facility. In-place removal can be mechanical or chemical. In-place paint stripping has the issue of proper disposal of the hazardous waste generated.

Mechanical stripping scrapes the paint off the substrate. Most times dry scraping is prohibited, but sanding or scraping can be done in conjunction with engineering controls to reduce airborne and settled lead dust. Power tools used to remove the paint must be equipped with a HEPA filtered shroud. Wetting a surface and hand scraping is also permitted. The components most often chosen for hand scraping are window and door jambs. Power tools are better equipped to handle lager surface areas.

Chemical stripping in-place uses strong chemicals to soften the paint for easier removal from the substrate. The chemicals are either very acidic or very basic, so proper training and protection for the worker is imperative. Generally, the chemicals must remain in- place overnight, so maintaining a secure worksite separate from occupants is mandatory.

Off site facilities use much stronger chemicals to remove the lead-based paint from the component. Components often chosen for off-site paint removal are intricate metal pieces. Sometimes this method is used for intricate wood work, but the stronger chemicals soften the wood and can drive lead into the wood while removing the paint.

Procedures & Methodology

Location Conventions

When reviewing Appendix A "Floor Plan" and Appendix B "Lead-Based Paint Evaluation Report", you will notice that the letters A, B, C, and D or the numbers 1, 2, 3 and 4 are used to identify the location of specific components. The key to correct orientation is the location of the "A" or "1" wall. The "B" or "2" wall, "C" or "3" wall, and "D" or "4" wall run clockwise from the "A" or "1" wall. The Lead-Based Paint Evaluation Report lists this information under the "Wall" column. The "Location"

column uses numbering of replicated components starting with "1" at left and continuing sequentially to right respectively to describe the location of the component while facing the wall identified.

Paint Testing

X-Ray Fluorescence

X-Ray Fluorescence (XRF) paint testing is performed to detect the presence of lead on painted surfaces. The XRF instrument is state-of-the art equipment. XRF testing is usually the preferred method of testing, because it is non-destructive, quantitative and can be performed on the spot with acceptable accuracy. LEW Environmental Services, LLC. 's evaluators follow the manufacturer's suggested use and the Performance Characteristic Sheet of the XRF instrument being used. The results of the XRF testing are the basis for drawing conclusions and making recommendations in the report.

All LEW Environmental Services, LLC. 's evaluators follow 40 CFR 745 and the HUD Guidelines for testing lead using an XRF instrument. All federal, state and city regulations are followed when applicable. The evaluator will test one of each and every different type of testing combination (component) in each room being surveyed. Each XRF reading is assigned an exclusive sample reference number and a measurement that is stored in the instrument. Each sample reference number location is logged on the XRF instrument for future reference, testing location, and report generation. The above described testing format is followed unless otherwise not practical or if the evaluator's judgment decides to test in a different systematic approach.

It should be noted that detected lead levels below current levels still could create lead dust or leadcontaminated soil hazards if the paint is turned into dust by abrasion, scraping, or sanding leading to possible elevated blood lead levels. Lead poisoning is a cumulative affect. Should a child or an adult inhale or ingest sufficient quantities of low concentrations of leaded paint, dust, or soil, it will accumulate in the body's systems and could eventually cumulate to an elevated blood level of concern.

Any untested building components should be considered lead-based paint until tested.

Calibration Check Readings

In addition to the manufacturer's recommended warm up and quality control procedures, LEW Environmental Services, LLC. collects quality control readings as recommended in the HUD Guidelines. Quality control for XRF instrumentation instruments involves readings to check calibration.

For each XRF instrument, one set of XRF calibration check readings are recommended at least every four hours. The first is a set of three nominal-time or source decay corrected time XRF calibration check readings to be taken before the inspection begins for the day. The second occurs either after the day's inspection work has been completed, or at least every four hours, whichever occurs first. LEW Environmental Services, LLC. 's XRF calibration check readings are taken on the Standard Reference Material (SRM) paint film nearest to 1.0 mg/cm² within the National Institute of Standards and Technology (NIST) SRM Used or the XRF manufacturer's factory supplied SRM film. Three readings are collected on the SRM. The average of the three readings on the SRM must be within the acceptable plus and minus tolerances for proper calibration as detailed in the Performance Characteristic Sheet (PCS). All calibration checks are taken with the SRM film positioned at least several inches away from any potential source of lead.

Three readings are taken each time calibration check readings are made. The average of the readings are compared to the known value and if the average value is within the acceptable calibration check tolerance specified in the XRF Performance Characteristic Sheet the instrument is considered in control. If the average readings are not within the calibration check tolerance the instrument is not used until the instrument is brought back into control.

LEW Corporation
Heuresis
Pb200i
1834
n units: mg/cm2
162
1
Action Level
Paint

6061133

6061133

39453

39454

-0.2 Negative

0 Negative

FALSE

FALSE

FALSE

FALSE

6/6/2024

12:22 PM Paint

6/6/2024 12:23 PM Paint

Job Id Reading # Result Calibration **RTA Present** Analytic Mode Site Address Area Unit # Room Structure Member Substrate Wall Location Concentration Date Time 6061133 39414 0.8 TRUE FALSE 6/6/2024 11:34 AM Paint 439 Victory Ave 6061133 39415 0.9 6/6/2024 11:35 AM Paint TRUE FALSE 439 Victory Ave 1 6061133 39416 TRUE FALSE 6/6/2024 11:35 AM Paint 439 Victory Ave 6061133 39417 -0.1 TRUE FALSE 6/6/2024 11:36 AM Paint 439 Victory Ave 6061133 39418 -0.1 TRUE FALSE 6/6/2024 11:36 AM Paint 439 Victory Ave 6061133 39419 -0.1 TRUE FALSE 6/6/2024 11:37 AM Paint 439 Victory Ave 0 Negative FALSE FALSE 6/6/2024 12:07 PM Paint 439 Victory Ave 6061133 39420 Unit Fover Door Metal 6061133 39421 -0.1 Negative FALSE FALSE 6/6/2024 12:08 PM Paint 439 Victory Ave Unit Foyer Door Casing Wood Δ 6061133 39422 -0.1 Negative FALSE FALSE 6/6/2024 12:08 PM Paint 439 Victory Ave Unit Foyer Window Wood Casing 6061133 39423 -0.2 Negative FALSE FALSE 6/6/2024 12:08 PM Paint 439 Victory Ave Unit Foyer Window Jamb Wood 6061133 39424 0 Negative FALSE FALSE 6/6/2024 12:09 PM Paint 439 Victory Ave Unit Foyer Closet **Bi-Fold Door** Wood в 1 6061133 39425 -0.1 Negative FALSE FALSE 6/6/2024 12:09 PM Paint 439 Victory Ave Unit Foyer Closet Door Casing Wood 1 6061133 39426 0 Negative FALSE FALSE 6/6/2024 12:10 PM Paint 439 Victory Ave Unit Foyer Wall Closet Drywall 12:10 PM Paint 6061133 39427 -0.1 Negative FALSE FALSE 6/6/2024 439 Victory Ave Unit Wall Drywall Foyer Room А 6061133 39428 0 Negative FALSE FALSE 6/6/2024 12:11 PM Paint 439 Victory Ave Unit Wall Foyer Room Drywall 1 6061133 39429 0 Negative FALSE FALSE 6/6/2024 12:11 PM Paint 439 Victory Ave Unit Fover Room Wall Drywal 6061133 39430 -0.1 Negative FALSE FALSE 6/6/2024 12:12 PM Paint 439 Victory Ave Unit Foyer Room Wall Drywall D 6061133 39431 0.1 Negative FALSE FALSE 6/6/2024 12:12 PM Paint 439 Victory Ave Unit Foyer Ceiling Drywall Room 6061133 39432 -0.1 Negative FALSE FALSE 6/6/2024 12:12 PM Paint 439 Victory Ave Unit Wood Foyer Room Baseboard 0 Negative 6061133 39433 FALSE FALSE 6/6/2024 12:13 PM Paint 439 Victory Ave Unit Living Room/Dining Room Wood Room Baseboard 1 6/6/2024 6061133 39434 -0.1 Negative FALSE FALSE 12:14 PM Paint 439 Victory Ave Unit Living Room/Dining Room Ceiling Drywall 1 Room 6061133 39435 0 Negative FALSE FALSE 6/6/2024 12:14 PM Paint 439 Victory Ave Unit Living Room/Dining Room Room Wall Drywal FALSE 6061133 39436 0 Negative FALSE 6/6/2024 12:15 PM Paint 439 Victory Ave Unit Living Room/Dining Room Wall Drywall в Room 6061133 39437 FALSE FALSE 6/6/2024 12:15 PM Paint 0 Negative 439 Victory Ave Unit Living Room/Dining Room Room Wall Drywall 12:15 PM Paint 6061133 FALSE 6/6/2024 Wall 39438 0 Negative FALSE 439 Victory Ave Unit Living Room/Dining Room Room Drywal 6061133 39439 -0.1 Negative FALSE FALSE 6/6/2024 12:16 PM Paint 439 Victory Ave Unit Living Room/Dining Room Door Wood D 6061133 39440 -0.2 Negative FALSE FALSE 6/6/2024 12:16 PM Paint 439 Victory Ave Unit Living Room/Dining Room Door Casing Wood D 6061133 FALSE FALSE 6/6/2024 12:17 PM Paint 39441 0 Negative 439 Victory Ave Unit Living Room/Dining Room Door Jamb Wood D 6061133 39442 FALSE 6/6/2024 -0.3 Negative FALSE 12:17 PM Paint 439 Victory Ave Unit Window Wood В Living Room/Dining Room Jamb 1 6/6/2024 6061133 39443 -0.1 Negative FALSE FALSE 12:18 PM Paint 439 Victory Ave Unit Living Room/Dining Room Window Sill Wood 1 R 39444 6/6/2024 6061133 -0.2 Negative FALSE FALSE 12:18 PM Paint 439 Victory Ave Unit Living Room/Dining Room Window Wood Casing 6061133 39445 0 Negative FALSE FALSE 6/6/2024 12:19 PM Paint 439 Victory Ave Unit Living Room/Dining Room Stair Balusters Wood В 6061133 39446 -0.1 Negative FALSE FALSE 6/6/2024 12:19 PM Paint 439 Victory Ave Unit Living Room/Dining Room Stair Railing Wood 6061133 -0.1 Negative FALSE 6/6/2024 12:19 PM Paint 39447 FALSE 439 Victory Ave Unit Living Room/Dining Room Stair Newel Post Wood 39448 0 Negative 6061133 FALSE FALSE 6/6/2024 12:20 PM Paint 439 Victory Ave Unit Kitchen Room Wall Drywall 6061133 39449 0.1 Negative FALSE FALSE 6/6/2024 12:21 PM Paint 439 Victory Ave Unit Kitchen Wall Room Drywall 6061133 0 Negative FALSE FALSE 6/6/2024 12:21 PM Paint Wall 39450 439 Victory Ave Unit Kitchen Drywall Room 6061133 39451 0.1 Negative FALSE FALSE 6/6/2024 12:21 PM Paint 439 Victory Ave Unit Kitchen Wall Drywall Room D 6/6/2024 39452 6061133 0.1 Negative FALSE FALSE 12:22 PM Paint 439 Victory Ave Unit Kitchen Room Ceiling Drywall D 1

439 Victory Ave

439 Victory Ave

Unit

Unit

Kitchen

Kitchen

Room

Closet

Baseboard

Door

Wood

Wood

А

All Readings

Job Id	Reading #	Concentration Result	Calibration	RTA Present	Date	Time	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
6061133	39455	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit	Office #	Kitchen	Closet	Door Casing	Wood	Δ	1
6061133	39456	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Kitchen	Closet	Door Jamb	Wood	^	1
6061133	39457	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Kitchen	Window	Casing	Wood	C C	1
6061133	39458	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Kitchen	Window	Jamb	Wood	C C	1
6061133	39458	×	FALSE	FALSE	6/6/2024			,			Kitchen		Sill	Wood	C C	1
6061133	39439	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave 439 Victory Ave	Unit		Kitchen	Window		Wood	C C	1
		0.1 Negative	-		6/6/2024				Unit			Cabinets	Door		C	1
6061133	39461	-0.2 Negative	FALSE	FALSE				439 Victory Ave	Unit		Kitchen	Cabinets	Frame	Wood	C	1
6061133	39462	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Room	Wall	Drywall	A	1
6061133	39463	-0.3 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Room	Wall	Drywall	В	1
6061133	39464	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Room	Wall	Drywall		
6061133	39465	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Room	Wall	Drywall	D	1
6061133	39466	0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Room	Ceiling	Drywall	D	1
6061133	39467	-0.3 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Room	Baseboard	Wood	D	1
6061133	39468	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Door		Metal	D	1
6061133	39469	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Door	Jamb	Wood	D	1
6061133	39470	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Door	Casing	Wood	D	1
6061133	39471	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Door		Wood	C	1
6061133	39472	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Closet	Door	Wood	С	1
6061133	39473	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Closet	Door Casing	Wood	С	1
6061133	39474	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Mud Room	Closet	Wall	Drywall	С	1
6061133	39475	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 1	Door		Wood	A	1
6061133	39476	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 1	Door	Jamb	Wood	A	1
6061133	39477	-0.1 Negative	FALSE	FALSE	6/6/2024		Paint	439 Victory Ave	Unit		Bathroom 1	Door	Casing	Wood	A	1
6061133	39478	0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 1	Cabinets	Door	Wood	D	1
6061133	39479	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 1	Cabinets	Frame	Wood	D	1
6061133	39480	-0.2 Negative	FALSE	FALSE	6/6/2024		Paint	439 Victory Ave	Unit		Bathroom 1	Window	Jamb	Wood	С	1
6061133	39481	-0.1 Negative	FALSE	FALSE	6/6/2024		Paint	439 Victory Ave	Unit		Bathroom 1	Window	Casing	Wood	С	1
6061133	39482	0.1 Negative	FALSE	FALSE	6/6/2024	12:38 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Window	Sill	Wood	С	1
6061133	39483	-0.3 Negative	FALSE	FALSE	6/6/2024	12:38 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Room	Baseboard	Wood	С	1
6061133	39484	0 Negative	FALSE	FALSE	6/6/2024	12:39 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Room	Ceiling	Drywall	A	1
6061133	39485	0 Negative	FALSE	FALSE	6/6/2024	12:39 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Room	Wall	Drywall	A	1
6061133	39486	0 Negative	FALSE	FALSE	6/6/2024	12:39 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Room	Wall	Drywall	В	1
6061133	39487	-0.1 Negative	FALSE	FALSE	6/6/2024	12:40 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Room	Wall	Drywall	С	1
6061133	39488	0.1 Negative	FALSE	FALSE	6/6/2024	12:40 PM	Paint	439 Victory Ave	Unit		Bathroom 1	Room	Wall	Drywall	D	1
6061133	39489	0.1 Negative	FALSE	FALSE	6/6/2024	12:41 PM	Paint	439 Victory Ave	Unit		Bedroom 1	Room	Wall	Drywall	D	1
6061133	39490	0 Negative	FALSE	FALSE	6/6/2024	12:41 PM		439 Victory Ave	Unit		Bedroom 1	Room	Wall	Drywall	С	1
6061133	39491	0 Negative	FALSE	FALSE	6/6/2024	12:42 PM	Paint	439 Victory Ave	Unit		Bedroom 1	Room	Wall	Drywall	В	1
6061133	39492	-0.1 Negative	FALSE	FALSE	6/6/2024	12:42 PM	Paint	439 Victory Ave	Unit		Bedroom 1	Room	Wall	Drywall	A	1
6061133	39493	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 1	Room	Baseboard	Wood	A	1
6061133	39494	-0.2 Negative	FALSE	FALSE	6/6/2024	12:43 PM	Paint	439 Victory Ave	Unit		Bedroom 1	Door	Casing	Wood	А	1
6061133	39495	0 Negative	FALSE	FALSE	6/6/2024	12:43 PM	Paint	439 Victory Ave	Unit		Bedroom 1	Door	Jamb	Wood	А	1
6061133	39496		FALSE	FALSE		12:44 PM		439 Victory Ave			Bedroom 1	Door		Wood	А	1
6061133	39497	0.1 Negative	FALSE	FALSE	6/6/2024	12:44 PM		439 Victory Ave			Bedroom 1	Closet	Bi-Fold Door	Wood	А	1
6061133	39498		FALSE	FALSE	6/6/2024	12:45 PM	Paint	439 Victory Ave	Unit		Bedroom 1	Closet	Door Casing	Wood	А	1
6061133	39499	-0.2 Negative	FALSE	FALSE		12:45 PM		439 Victory Ave			Bedroom 1	Closet	Door Jamb	Wood	А	1
6061133	39500	0 Negative	FALSE	FALSE		12:46 PM		439 Victory Ave			Bedroom 1	Closet	Wall	Drywall	А	1
6061133	39501	-0.2 Negative	FALSE	FALSE		12:46 PM		439 Victory Ave	-		Bedroom 1	Window	Jamb	Wood	С	1
6061133	39502	0 Negative	FALSE	FALSE		12:47 PM		439 Victory Ave			Bedroom 1	Window	Casing	Wood	С	1
6061133	39503	-0.4 Negative	FALSE	FALSE		12:47 PM		439 Victory Ave			Bedroom 1	Window	Sill	Wood	С	1
6061133	39504	0 Negative	FALSE	FALSE		12:48 PM		439 Victory Ave			2nd Floor Hallway	Room	Wall	Drywall	A	1
6061133	39505		FALSE	FALSE		12:49 PM		439 Victory Ave			2nd Floor Hallway	Room	Wall	Drywall	В	1
5001155	33303	J.2 Negative	I ALUL	I ALUL	3, 3, 2024	12.331101		The the terms and the	Unit					J , Wun	1	1


Job Id	Reading #	Concentration Result	Calibration	RTA Present	Date	Time	Analytic Mode	Site Address	Area	Unit #	Boom	Structure	Member	Substrate	Wall	Location
6061133	39506	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit	Unit #	2nd Floor Hallway	Room	Wall	Drywall	C	1
6061133	39507	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		2nd Floor Hallway	Room	Ceiling	Drywall	c	1
6061133	39508	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		2nd Floor Hallway	Room	Baseboard	Wood	c	1
6061133	39509	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		2nd Floor Hallway	Door		Wood	c	1
6061133	39510	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		2nd Floor Hallway	Door	Jamb	Wood	c	1
6061133	39510	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		2nd Floor Hallway	Door	Casing	Wood	c	1
6061133	39512	-0.1 Negative		FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Door	Casing	Wood	D	1
6061133	39512	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Door	Jamb	Wood	D	1
6061133	39514	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Door		Wood	D	1
6061133	39515	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Cabinets	Door	Wood	C	1
6061133	39516	0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Cabinets	Frame	Wood	C	1
6061133	39517	-0.3 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Room	Baseboard	Wood	Δ	1
6061133	39518	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Room	Wall	Drywall	Δ	1
6061133	39519	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Room	Wall	Drywall	В	1
6061133	39520	0 Negative	-	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Room	Wall	Drywall	C	1
6061133	39520	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Room	Wall	Drywall	D	1
6061133	39522	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bathroom 2	Room	Ceiling	Drywall	D	1
6061133	39522	-0.1 Negative	-	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 2	Room	Ceiling	Drywall	Δ	1
6061133	39524	0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 2	Room	Wall	Drywall	Δ	1
6061133	39525	0 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 2	Room	Wall	Drywall	B	1
6061133	39526	-0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 2	Room	Wall	Drywall	C	1
6061133	39527	0.1 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 2	Room	Wall	Drywall	D	1
6061133	39528	-0.2 Negative	FALSE	FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 2	Room	Baseboard	Drywall	D	1
6061133	39529	0.1 Negative	FALSE	FALSE	6/6/2024	1:00 PM		439 Victory Ave	Unit		Bedroom 2	Bookcase	Shelf	Drywall	D	1
6061133	39530	0 Negative	FALSE	FALSE	6/6/2024	1:00 PM		439 Victory Ave	Unit		Bedroom 2	Bookcase	Frame	Wood	D	1
6061133	39531	-0.1 Negative	FALSE	FALSE	6/6/2024	1:00 PM		439 Victory Ave	Unit		Bedroom 2	Window	Jamb	Wood	Δ	1
6061133	39532	-0.2 Negative	FALSE	FALSE	6/6/2024	1:01 PM		439 Victory Ave	Unit		Bedroom 2	Window	Casing	Wood	A	1
6061133	39533	-0.1 Negative	FALSE	FALSE	6/6/2024	1:02 PM		439 Victory Ave	Unit		Bedroom 2	Window	Sill	Wood	Δ	1
6061133	39534	-0.1 Negative	FALSE	FALSE	6/6/2024	1:02 PM		439 Victory Ave	Unit		Bedroom 2	Closet	Door	Wood	В	1
6061133	39535	-0.2 Negative	FALSE	FALSE	6/6/2024	1:03 PM		439 Victory Ave	Unit		Bedroom 2	Closet	Door Casing	Wood	В	1
6061133	39536	0 Negative		FALSE	6/6/2024	1:03 PM		439 Victory Ave	Unit		Bedroom 2	Closet	Door Jamb	Wood	В	1
6061133	39537	0 Negative	FALSE	FALSE	6/6/2024	1:03 PM		439 Victory Ave	Unit		Bedroom 2	Closet	Wall	Drywall	B	1
6061133	39538	-0.1 Negative		FALSE	6/6/2024	1:04 PM		439 Victory Ave	Unit		Bedroom 2	Door		Wood	c	1
6061133	39539	0 Negative	FALSE	FALSE	6/6/2024	1:04 PM		439 Victory Ave	Unit		Bedroom 2	Door	Jamb	Wood	c	1
6061133	39540	-0.1 Negative	FALSE	FALSE	6/6/2024	1:05 PM		439 Victory Ave	Unit		Bedroom 2	Door	Casing	Wood	C	1
6061133	39541	-0.2 Negative	FALSE	FALSE	6/6/2024	1:05 PM		439 Victory Ave	Unit		Bedroom 3	Door	Casing	Wood	A	1
6061133	39542	0.1 Negative	FALSE	FALSE	6/6/2024	1:06 PM		439 Victory Ave	Unit		Bedroom 3	Door	Jamb	Wood	A	1
6061133	39543	0 Negative	FALSE	FALSE	6/6/2024	1:06 PM		439 Victory Ave	Unit		Bedroom 3	Door		Wood	A	1
6061133	39544	0.2 Negative	FALSE	FALSE	6/6/2024	1:07 PM		439 Victory Ave	Unit		Bedroom 3	Closet	Door	Wood	В	1
6061133	39545	-0.1 Negative		FALSE	6/6/2024	1:07 PM		439 Victory Ave	Unit		Bedroom 3	Closet	Door Casing	Wood	В	1
6061133	39546			FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Closet		Wood	В	1
6061133	39547	0 Negative		FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Closet	Wall	Drywall	В	1
6061133	39548			FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Window	Jamb	Wood	С	1
6061133	39549			FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Window	Casing	Wood	С	1
6061133	39550	-0.2 Negative		FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Window	Sill	Wood	С	1
6061133	39551	0.1 Negative		FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Bookcase	Shelf	Wood	D	1
6061133	39552	-0.2 Negative		FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Bookcase	Frame	Wood	D	1
6061133	39553	-0.2 Negative		FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Room	Baseboard	Wood	D	1
6061133	39554	0 Negative		FALSE	6/6/2024			439 Victory Ave	Unit		Bedroom 3	Room	Ceiling	Drywall	D	1
6061133	39555	0 Negative		FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Room	Wall	Drywall	D	1
6061133	39556			FALSE	6/6/2024			439 Victory Ave			Bedroom 3	Room	Wall	Drywall	С	1

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
6061133	39557	0	Negative	FALSE	FALSE	6/6/2024	1:12 PM	Paint	439 Victory Ave	Unit		Bedroom 3	Room	Wall	Drywall	В	1
6061133	39558	0	Negative	FALSE	FALSE	6/6/2024	1:13 PM	Paint	439 Victory Ave	Unit		Bedroom 3	Room	Wall	Drywall	А	1
6061133	39559	0.1	Negative	FALSE	FALSE	6/6/2024	1:14 PM	Paint	439 Victory Ave	Unit		Basement room 1	Stair	Treads	Wood	С	1
6061133	39560	-0.1	Negative	FALSE	FALSE	6/6/2024	1:14 PM	Paint	439 Victory Ave	Unit		Basement room 1	Stair	Stringer	Wood	С	1
6061133	39561	0	Negative	FALSE	FALSE	6/6/2024	1:15 PM	Paint	439 Victory Ave	Unit		Basement room 1	Door		Wood	С	1
6061133	39562	0	Negative	FALSE	FALSE	6/6/2024	1:15 PM	Paint	439 Victory Ave	Unit		Basement room 1	Door	Jamb	Wood	С	1
6061133	39563	0.2	Negative	FALSE	FALSE	6/6/2024	1:16 PM	Paint	439 Victory Ave	Unit		Basement room 1	Room	Floor	Concrete	А	1
6061133	39564	0	Negative	FALSE	FALSE	6/6/2024	1:17 PM	Paint	439 Victory Ave	Unit		Basement room 1	Room	Wall	Concrete	А	1
6061133	39565	0.1	Negative	FALSE	FALSE	6/6/2024	1:18 PM	Paint	439 Victory Ave	Unit		Basement room 1	Room	Wall	Concrete	В	1
6061133	39566	0.4	Negative	FALSE	FALSE	6/6/2024	1:19 PM	Paint	439 Victory Ave	Unit		Basement room 1	Room	Wall	Concrete	С	1
6061133	39567	0.1	Negative	FALSE	FALSE	6/6/2024	1:19 PM	Paint	439 Victory Ave	Unit		Basement room 1	Room	Wall	Concrete	D	1
6061133	39568	0	Negative	FALSE	FALSE	6/6/2024	1:19 PM	Paint	439 Victory Ave	Unit		Basement room 1	Room	Ceiling	Concrete	D	1
6061133	39569	0	Negative	FALSE	FALSE	6/6/2024	1:20 PM	Paint	439 Victory Ave	Unit		Basement room 1	Window	Casing	Wood	В	1
6061133	39570	-0.1	Negative	FALSE	FALSE	6/6/2024	1:21 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Window	Jamb	Wood	В	1
6061133	39571	-0.1	Negative	FALSE	FALSE	6/6/2024	1:22 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Door		Wood	С	1
6061133	39572	5.2	Positive	FALSE	FALSE	6/6/2024	1:22 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Door	Jamb	Wood	С	1
6061133	39573	1.3	Positive	FALSE	FALSE	6/6/2024	1:23 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Screen Door		Wood	С	2
6061133	39574	0.1	Negative	FALSE	FALSE	6/6/2024	1:24 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Window	Jamb	Wood	С	1
6061133	39575	0.1	Negative	FALSE	FALSE	6/6/2024	1:25 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Room	Floor	Concrete	В	1
6061133	39576	0.3	Negative	FALSE	FALSE	6/6/2024	1:26 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Room	Wall	Concrete	В	1
6061133	39577	0.3	Negative	FALSE	FALSE	6/6/2024	1:27 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Room	Wall	Drywall	В	Upper
6061133	39578	0.2	Negative	FALSE	FALSE	6/6/2024	1:28 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Room	Wall	Drywall	С	Upper
6061133	39579	0.1	Negative	FALSE	FALSE	6/6/2024	1:28 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Room	Wall	Concrete	С	Lower
6061133	39580	0	Negative	FALSE	FALSE	6/6/2024	1:29 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Room	Wall	Concrete	D	1
6061133	39581	0.4	Negative	FALSE	FALSE	6/6/2024	1:29 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Pipe	Vertical	Metal	С	1
6061133	39582	1		TRUE	FALSE	6/6/2024	1:30 PM	Paint	439 Victory Ave								
6061133	39583	0.9		TRUE	FALSE	6/6/2024	1:31 PM	Paint	439 Victory Ave								
6061133	39584	0.9		TRUE	FALSE	6/6/2024	1:31 PM	Paint	439 Victory Ave								
6061133	39585	-0.1		TRUE	FALSE	6/6/2024	1:32 PM	Paint	439 Victory Ave								
6061133	39586	-0.1		TRUE	FALSE	6/6/2024	1:32 PM	Paint	439 Victory Ave								
6061133	39587	-0.1		TRUE	FALSE	6/6/2024	1:33 PM	Paint	439 Victory Ave								

Company	LEW Corporation		
XRF Make	Heuresis		
Model	Pb200i		
Serial Num.	1834		
Lead concentration	on units: mg/cm2		Actionables
Total Readings:	162 Total Positives	2	
Action Level	1		
Mode	Action Level		
Analytic Mode	Paint		

J	ob Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
	6061133	39572	5.2	Positive	FALSE	FALSE	6/6/2024	1:22 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Door	Jamb	Wood	С	1
	6061133	39573	1.3	Positive	FALSE	FALSE	6/6/2024	1:23 PM	Paint	439 Victory Ave	Unit		Basement Room 2	Screen Door		Wood	С	2

Floor Plan(s)





It is hereby certified that a lead-based paint inspection, has been performed, and the results of this inspection indicate that no lead in the amount greater than or equal to 1.0 mg/cm² or greater than 0.5 % by weight in paint, was found on any building component using the protocols outlined in **N.J.A.C. 5:17-3.2(c)**. Therefore, the dwelling(s) identified below qualify for the following exemption.

	N.J.A.C. 5:10-1.12(h)4	(Additional Lead Paint Fee)	BHI Registration Num	ber:N/A
	N.J.A.C. 5:10-6.6	(Lead-Safe Maintenance)		
	N.J.A.C. 5:27-4.10(a)1 OR N.J.A.C. 5:15-4.2(c) (Rooming & Boarding OR Emergency Shelters) Facility ID:			
\boxtimes	N.J.A.C. 5:28-2.1(a)	State Housing Code		
CHILD OCCUPIED FACILITY (Daycare Centers, Preschools, etc.) PURSUANT TO N.J.A.C. 5:17				
Site Address: <u>439 Victory Ave Pohatcong Township, NJ 08865</u> County: <u>Warren</u> Block: <u>11.02</u> Lot: <u>8</u>				
Applicable Units or Common Areas: Interior only				
Name of Inspector / Risk Assessor: <u>Neheru Singh</u> NJDOH ID #: <u>027180</u>				
Name of Evaluation Contractor: LEW Environmental Services, LLC				_NJDCA CERT. #: <u>00015</u>
Address of Evaluation Contractor: <u>181 US Hwy 46, Mine Hill, NJ 07803</u>				Phone #: <u>(908) 654-8068</u>
Date(s) of Inspection: <u>06/ 06/ 2024 TO 06/ 17/2024</u> Date Certificate Issued: <u>06/ 25/ 2024</u>				
lul.				

Signature of Inspector / Risk Assessor: Work and the

THIS CERTIFICATE SHOULD BE KEPT BY THE OWNER AND TRANSFERRED TO ALL FUTURE OWNERS FOR LIFE OF STRUCTURE