

Company LEW Corporation  
 XRF Make Heuresis  
 Model Pb200i  
 Serial Num. 1832  
 Lead concentration units: mg/cm2  
 Total Readings: 69  
 Action Level 1  
 Mode Action Level  
 Analytic Mode Paint

All Readings

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
10311143	1392	1.1		TRUE	FALSE	10/31/2024	11:44 AM	Saheed Alex Adeyeri	Paint											
10311143	1393	1.1		TRUE	FALSE	10/31/2024	11:44 AM	Saheed Alex Adeyeri	Paint											
10311143	1394	1		TRUE	FALSE	10/31/2024	11:44 AM	Saheed Alex Adeyeri	Paint											
10311143	1395	0		TRUE	FALSE	10/31/2024	11:44 AM	Saheed Alex Adeyeri	Paint											
10311143	1396	0		TRUE	FALSE	10/31/2024	11:45 AM	Saheed Alex Adeyeri	Paint											
10311143	1397	0		TRUE	FALSE	10/31/2024	11:45 AM	Saheed Alex Adeyeri	Paint											
10311143	1398	-0.1	Negative	FALSE	FALSE	10/31/2024	11:47 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Room	Wall	Drywall	A		Intact	
10311143	1399	-0.1	Negative	FALSE	FALSE	10/31/2024	11:47 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Room	Wall	Drywall	B		Intact	
10311143	1400	0	Negative	FALSE	FALSE	10/31/2024	11:47 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Room	Wall	Drywall	C		Intact	
10311143	1401	0.1	Negative	FALSE	FALSE	10/31/2024	11:48 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Room	Wall	Drywall	D		Intact	
10311143	1402	-0.1	Negative	FALSE	FALSE	10/31/2024	11:49 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Room	Baseboard	Wood	D		Intact	
10311143	1403	0	Negative	FALSE	FALSE	10/31/2024	11:49 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Casing	Wood	A		Intact	
10311143	1404	-0.3	Negative	FALSE	FALSE	10/31/2024	11:50 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Casing	Wood	B		Intact	
10311143	1405	-0.3	Negative	FALSE	FALSE	10/31/2024	11:50 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Casing	Wood	A		Intact	
10311143	1406	0.1	Negative	FALSE	FALSE	10/31/2024	11:50 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	---	Wood	A		Intact	
10311143	1407	-0.2	Negative	FALSE	FALSE	10/31/2024	11:51 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Casing	Wood	B		Intact	
10311143	1408	-0.2	Negative	FALSE	FALSE	10/31/2024	11:51 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Jamb	Wood	B		Intact	
10311143	1409	-0.3	Negative	FALSE	FALSE	10/31/2024	11:52 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	---	Wood	B		Intact	
10311143	1410	0	Negative	FALSE	FALSE	10/31/2024	11:52 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Window	Casing	Wood	B		Intact	
10311143	1411	-0.1	Negative	FALSE	FALSE	10/31/2024	11:53 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Window	Jamb	Wood	B		Intact	
10311143	1412	0	Negative	FALSE	FALSE	10/31/2024	11:53 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Window	Sill	Wood	B		Intact	
10311143	1413	0	Negative	FALSE	FALSE	10/31/2024	11:54 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Casing	Wood	D		Intact	
10311143	1414	-0.1	Negative	FALSE	FALSE	10/31/2024	11:54 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	Jamb	Wood	D		Intact	
10311143	1415	0	Negative	FALSE	FALSE	10/31/2024	11:54 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Living Room	Door	---	Wood	D		Intact	
10311143	1416	0	Negative	FALSE	FALSE	10/31/2024	11:55 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Room	Wall	Drywall	A		Intact	
10311143	1417	0	Negative	FALSE	FALSE	10/31/2024	11:55 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Room	Wall	Drywall	B		Intact	
10311143	1418	0.1	Negative	FALSE	FALSE	10/31/2024	11:56 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Room	Wall	Drywall	C		Intact	
10311143	1419	0.2	Negative	FALSE	FALSE	10/31/2024	11:56 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Room	Wall	Drywall	D		Intact	
10311143	1420	0.1	Negative	FALSE	FALSE	10/31/2024	11:56 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Closet	Door	Wood	D		Intact	
10311143	1421	-0.1	Negative	FALSE	FALSE	10/31/2024	11:57 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Closet	Door Casing	Wood	D		Intact	
10311143	1422	0	Negative	FALSE	FALSE	10/31/2024	11:57 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Closet	Door Jamb	Wood	D		Intact	
10311143	1423	0	Negative	FALSE	FALSE	10/31/2024	11:57 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Door	Casing	Wood	C		Intact	
10311143	1424	0.1	Negative	FALSE	FALSE	10/31/2024	11:58 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Door	Jamb	Wood	C		Intact	
10311143	1425	-0.3	Negative	FALSE	FALSE	10/31/2024	11:58 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 2	Door	---	Wood	C		Intact	
10311143	1426	-0.2	Negative	FALSE	FALSE	10/31/2024	11:58 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Door	---	Wood	B		Intact	
10311143	1427	0	Negative	FALSE	FALSE	10/31/2024	11:59 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Door	Casing	Wood	B		Intact	
10311143	1428	0.1	Negative	FALSE	FALSE	10/31/2024	11:59 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Door	Jamb	Wood	B		Intact	
10311143	1429	-0.1	Negative	FALSE	FALSE	10/31/2024	11:59 AM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Window	Casing	Wood	D		Intact	
10311143	1430	0	Negative	FALSE	FALSE	10/31/2024	12:00 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Window	Jamb	Wood	D		Intact	
10311143	1431	0	Negative	FALSE	FALSE	10/31/2024	12:00 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Window	Sill	Wood	D		Intact	
10311143	1432	-0.1	Negative	FALSE	FALSE	10/31/2024	12:00 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Room	Wall	Drywall	A		Intact	
10311143	1433	-0.1	Negative	FALSE	FALSE	10/31/2024	12:01 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Room	Wall	Drywall	B		Intact	
10311143	1434	0	Negative	FALSE	FALSE	10/31/2024	12:01 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Room	Wall	Drywall	C		Intact	
10311143	1435	0	Negative	FALSE	FALSE	10/31/2024	12:01 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bedroom 1	Room	Wall	Drywall	D		Intact	
10311143	1436	0.1	Negative	FALSE	FALSE	10/31/2024	12:02 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bathroom	Room	Wall	Drywall	A		Intact	
10311143	1437	0.1	Negative	FALSE	FALSE	10/31/2024	12:02 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bathroom	Room	Wall	Drywall	B		Intact	
10311143	1438	0.3	Negative	FALSE	FALSE	10/31/2024	12:02 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bathroom	Room	Wall	Drywall	C		Intact	
10311143	1439	-0.1	Negative	FALSE	FALSE	10/31/2024	12:03 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bathroom	Room	Wall	Drywall	D		Intact	
10311143	1440	-0.1	Negative	FALSE	FALSE	10/31/2024	12:03 PM	Saheed Alex Adeyeri	Paint	81 Railroad Ave	Unit A	A	Bathroom	Window	Casing	Wood	D		Intact	



Company LEW Corporation  
 XRF Make Heuresis  
 Model Pb200i  
 Serial Num. 1832  
 Lead concentration units: mg/cm2  
 Total Readings: 69 Total Positives 0  
 Action Level 1  
 Mode Action Level  
 Analytic Mode Paint

**Actionables**

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
No Actionables																				

Company LEW Corporation  
 XRF Make Heuresis  
 Model Pb200i  
 Serial Num. 1832  
 Lead concentration units: mg/cm2  
 Total Readings: 69 Total Hazards 0  
 Action Level 1  
 Mode Action Level  
 Analytic Mode Paint

**Hazards**

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
No Hazards																				