

Company LEW Corporation
 XRF Make Heuresis
 Model Pb200i
 Serial Num. 2128
 Lead concentration units: mg/cm2
 Total Readings: 91
 Action Level 1
 Mode Action Level
 Analytic Mode Paint

All Readings

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
6051436	22126	0.9		TRUE	FALSE	6/5/2024	2:37 PM	Danny Feliciano	Paint	105 Monroe Ave								
6051436	22127	1		TRUE	FALSE	6/5/2024	2:38 PM	Danny Feliciano	Paint	105 Monroe Ave								
6051436	22128	1		TRUE	FALSE	6/5/2024	2:38 PM	Danny Feliciano	Paint	105 Monroe Ave								
6051436	22129	0.1		TRUE	FALSE	6/5/2024	2:39 PM	Danny Feliciano	Paint	105 Monroe Ave								
6051436	22130	0		TRUE	FALSE	6/5/2024	2:39 PM	Danny Feliciano	Paint	105 Monroe Ave								
6051436	22131	0.1		TRUE	FALSE	6/5/2024	2:40 PM	Danny Feliciano	Paint	105 Monroe Ave								
6051436	22132	-0.1	Negative	FALSE	FALSE	6/5/2024	2:41 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Door	---	Metal	A	
6051436	22133	-0.2	Negative	FALSE	FALSE	6/5/2024	2:41 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Door	Casing	Wood	A	
6051436	22134	-0.1	Negative	FALSE	FALSE	6/5/2024	2:42 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Baseboard	Wood	B	
6051436	22135	-0.6	Negative	FALSE	TRUE	6/5/2024	2:42 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Door	Casing	Wood	B	
6051436	22136	0	Negative	FALSE	FALSE	6/5/2024	2:44 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Door	Jamb	Wood	B	
6051436	22137	0.2	Negative	FALSE	FALSE	6/5/2024	2:44 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Wall	Drywall	B	
6051436	22138	0.2	Negative	FALSE	FALSE	6/5/2024	2:45 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Wall	Drywall	C	
6051436	22139	0.5	Negative	FALSE	FALSE	6/5/2024	2:45 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Wall	Drywall	D	
6051436	22140	0.3	Negative	FALSE	FALSE	6/5/2024	2:46 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Wall	Drywall	A	
6051436	22141	0	Negative	FALSE	FALSE	6/5/2024	2:46 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Window	Casing	Wood	D	
6051436	22142	0.2	Negative	FALSE	FALSE	6/5/2024	2:47 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Window	Sill	Wood	D	
6051436	22143	0.3	Negative	FALSE	FALSE	6/5/2024	2:47 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Ceiling	Drywall		
6051436	22144	0.1	Negative	FALSE	FALSE	6/5/2024	2:49 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Door	Jamb	Wood	D	
6051436	22145	-0.4	Negative	FALSE	TRUE	6/5/2024	2:49 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Window	Casing	Wood	B	
6051436	22146	0.3	Negative	FALSE	FALSE	6/5/2024	2:50 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Window	Sill	Wood	B	
6051436	22147	-0.7	Negative	FALSE	TRUE	6/5/2024	2:50 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Baseboard	Wood	B	
6051436	22148	0	Negative	FALSE	FALSE	6/5/2024	2:51 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Wall	Drywall	B	
6051436	22149	-0.7	Negative	FALSE	TRUE	6/5/2024	2:51 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Wall	Drywall	C	
6051436	22150	-0.7	Negative	FALSE	TRUE	6/5/2024	2:51 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Wall	Drywall	D	
6051436	22151	-0.4	Negative	FALSE	TRUE	6/5/2024	2:52 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Wall	Drywall	A	
6051436	22152	0.2	Negative	FALSE	FALSE	6/5/2024	2:53 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Ceiling	Drywall		
6051436	22153	-0.9	Negative	FALSE	TRUE	6/5/2024	2:53 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Kitchen	Room	Crown Molding	Wood		
6051436	22154	-0.3	Negative	FALSE	TRUE	6/5/2024	2:55 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Room	Crown Molding	Wood		
6051436	22155	-0.4	Negative	FALSE	TRUE	6/5/2024	2:56 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Closet	Door	Wood	B	
6051436	22156	-0.6	Negative	FALSE	TRUE	6/5/2024	2:56 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Closet	Door Casing	Wood	B	
6051436	22157	0.1	Negative	FALSE	FALSE	6/5/2024	2:57 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Living Room	Closet	Door Jamb	Wood	B	
6051436	22158	0.3	Negative	FALSE	FALSE	6/5/2024	2:59 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Room	Wall	Drywall	A	
6051436	22159	0.2	Negative	FALSE	FALSE	6/5/2024	2:59 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Room	Wall	Drywall	C	
6051436	22160	0.4	Negative	FALSE	FALSE	6/5/2024	3:00 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Room	Wall	Drywall	B	
6051436	22161	-0.5	Negative	FALSE	TRUE	6/5/2024	3:00 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Door	Wood	A	1
6051436	22162	-0.4	Negative	FALSE	TRUE	6/5/2024	3:01 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Door Casing	Wood	A	1
6051436	22163	-0.2	Negative	FALSE	TRUE	6/5/2024	3:01 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Door	Wood	A	2
6051436	22164	-0.5	Negative	FALSE	TRUE	6/5/2024	3:02 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Door Casing	Wood	A	2
6051436	22165	0	Negative	FALSE	FALSE	6/5/2024	3:03 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Door Jamb	Wood	A	1
6051436	22166	0	Negative	FALSE	FALSE	6/5/2024	3:04 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Door Jamb	Wood	A	2
6051436	22167	-0.9	Negative	FALSE	TRUE	6/5/2024	3:04 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Shelf	Wood	A	2

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
6051436	22168	-0.3	Negative	FALSE	TRUE	6/5/2024	3:05 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Shelf Support	Wood	A	2
6051436	22169	-0.7	Negative	FALSE	TRUE	6/5/2024	3:06 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Shelf	Wood	A	1
6051436	22170	-0.5	Negative	FALSE	TRUE	6/5/2024	3:06 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Closet	Shelf Support	Wood	A	1
6051436	22171	-0.8	Negative	FALSE	TRUE	6/5/2024	3:07 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Door	Casing	Wood	B	
6051436	22172	0.2	Negative	FALSE	FALSE	6/5/2024	3:07 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Door	Jamb	Wood	B	
6051436	22173	-0.3	Negative	FALSE	TRUE	6/5/2024	3:08 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Door	---	Wood	B	
6051436	22174	0.4	Negative	FALSE	FALSE	6/5/2024	3:09 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Foyer/Hall	Room	Ceiling	Drywall		
6051436	22175	-0.6	Negative	FALSE	TRUE	6/5/2024	3:10 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Door	Casing	Wood	D	
6051436	22176	0.2	Negative	FALSE	FALSE	6/5/2024	3:10 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Door	Jamb	Wood	D	
6051436	22177	-0.6	Negative	FALSE	TRUE	6/5/2024	3:10 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Door	---	Wood	D	
6051436	22178	-0.1	Negative	FALSE	FALSE	6/5/2024	3:11 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Room	Baseboard	Wood	D	
6051436	22179	-0.4	Negative	FALSE	TRUE	6/5/2024	3:12 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Window	Casing	Wood	B	
6051436	22180	-0.6	Negative	FALSE	TRUE	6/5/2024	3:12 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Window	Sill	Wood	B	
6051436	22181	-0.8	Negative	FALSE	TRUE	6/5/2024	3:13 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Room	Wall	Drywall	C	
6051436	22182	-0.7	Negative	FALSE	TRUE	6/5/2024	3:13 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Room	Wall	Drywall	D	
6051436	22183	0.1	Negative	FALSE	FALSE	6/5/2024	3:16 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Room	Wall	Drywall	B	
6051436	22184	0.2	Negative	FALSE	FALSE	6/5/2024	3:17 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Room	Wall	Drywall	A	
6051436	22185	0.3	Negative	FALSE	FALSE	6/5/2024	3:18 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bathroom	Room	Ceiling	Drywall		
6051436	22186	0.2	Negative	FALSE	FALSE	6/5/2024	3:19 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Room	Ceiling	Drywall		
6051436	22187	0.1	Negative	FALSE	FALSE	6/5/2024	3:19 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Room	Wall	Drywall	C	
6051436	22188	0.2	Negative	FALSE	FALSE	6/5/2024	3:20 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Room	Wall	Drywall	B	
6051436	22189	0.1	Negative	FALSE	FALSE	6/5/2024	3:20 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Room	Wall	Drywall	A	
6051436	22190	0.3	Negative	FALSE	FALSE	6/5/2024	3:21 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Room	Wall	Drywall	D	
6051436	22191	0.3	Negative	FALSE	FALSE	6/5/2024	3:21 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Window	Casing	Wood	B	
6051436	22192	0.2	Negative	FALSE	FALSE	6/5/2024	3:22 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Window	Sill	Wood	B	
6051436	22193	0.1	Negative	FALSE	TRUE	6/5/2024	3:23 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Closet	Shelf Support	Wood	D	
6051436	22194	-0.3	Negative	FALSE	TRUE	6/5/2024	3:24 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Closet	Shelf	Wood	D	
6051436	22195	-0.3	Negative	FALSE	TRUE	6/5/2024	3:24 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Door		Wood	A	
6051436	22196	-0.8	Negative	FALSE	TRUE	6/5/2024	3:24 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Door	Casing	Wood	A	
6051436	22197	0.2	Negative	FALSE	FALSE	6/5/2024	3:25 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 1	Door	Jamb	Wood	A	
6051436	22198	0.3	Negative	FALSE	FALSE	6/5/2024	3:26 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Door	Jamb	Wood	B	
6051436	22199	-0.6	Negative	FALSE	TRUE	6/5/2024	3:26 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Door	Casing	Wood	B	
6051436	22200	-0.3	Negative	FALSE	TRUE	6/5/2024	3:27 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Door	---	Wood	B	
6051436	22201	0.2	Negative	FALSE	FALSE	6/5/2024	3:28 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Room	Wall	Drywall	B	
6051436	22202	0.1	Negative	FALSE	FALSE	6/5/2024	3:28 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Room	Wall	Drywall	C	
6051436	22203	0.1	Negative	FALSE	FALSE	6/5/2024	3:28 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Room	Wall	Drywall	D	
6051436	22204	0.1	Negative	FALSE	FALSE	6/5/2024	3:29 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Room	Wall	Drywall	A	
6051436	22205	0.2	Negative	FALSE	FALSE	6/5/2024	3:30 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Window	Casing	Wood	D	
6051436	22206	0.1	Negative	FALSE	FALSE	6/5/2024	3:30 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Window	Sill	Wood	D	
6051436	22207	-0.1	Negative	FALSE	FALSE	6/5/2024	3:31 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Closet	Shelf	Wood	B	
6051436	22208	0.1	Negative	FALSE	FALSE	6/5/2024	3:31 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Closet	Shelf Support	Wood	B	
6051436	22209	-0.1	Negative	FALSE	FALSE	6/5/2024	3:32 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Room	Ceiling	Plaster		
6051436	22210	-0.5	Negative	FALSE	TRUE	6/5/2024	3:33 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 2	Room	Crown Molding	Wood		
6051436	22211	0	Negative	FALSE	FALSE	6/5/2024	3:34 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Room	Ceiling	Wood		
6051436	22212	0.2	Negative	FALSE	FALSE	6/5/2024	3:35 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Room	Wall	Drywall	C	
6051436	22213	0.3	Negative	FALSE	FALSE	6/5/2024	3:36 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Room	Wall	Drywall	D	
6051436	22214	0.4	Negative	FALSE	FALSE	6/5/2024	3:37 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Room	Wall	Drywall	A	
6051436	22215	0.4	Negative	FALSE	FALSE	6/5/2024	3:37 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Room	Wall	Drywall	B	
6051436	22216	-0.7	Negative	FALSE	TRUE	6/5/2024	3:38 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Window	Casing	Wood	A	
6051436	22217	-0.1	Negative	FALSE	TRUE	6/5/2024	3:38 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Closet	Door	Wood	A	
6051436	22218	-0.2	Negative	FALSE	TRUE	6/5/2024	3:39 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Closet	Door Casing	Wood	A	
6051436	22219	-0.4	Negative	FALSE	TRUE	6/5/2024	3:39 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Closet	Door Jamb	Wood	A	
6051436	22220	-0.5	Negative	FALSE	TRUE	6/5/2024	3:40 PM	Danny Feliciano	Paint	105 Monroe Ave	Unit		Bedroom 3	Door		Wood	B	

Company LEW Corporation
XRF Make Heuresis
Model Pb200i
Serial Num. 2128

Lead concentration units: mg/cm2

Total Readings: 91 Total Positives 0

Action Level 1

Mode Action Level

Analytic Mode Paint

Actionables

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
No Actionables																		