

Company LEW Corporation
 XRF Make Heuresis
 Model Pb200i
 Serial Num. 2128
 Lead concentration units: mg/cm2
 Total Readings: 45
 Action Level 1
 Mode Action Level
 Analytic Mode Paint

All Readings

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
5241749	21571	1		TRUE	FALSE	5/24/2024	5:49 PM	Danny Feliciano	Paint	7 Alpine Dr								
5241749	21572	1		TRUE	FALSE	5/24/2024	5:49 PM	Danny Feliciano	Paint	7 Alpine Dr								
5241749	21573	1		TRUE	FALSE	5/24/2024	5:50 PM	Danny Feliciano	Paint	7 Alpine Dr								
5241749	21574	0		TRUE	FALSE	5/24/2024	5:51 PM	Danny Feliciano	Paint	7 Alpine Dr								
5241749	21575	0		TRUE	FALSE	5/24/2024	5:51 PM	Danny Feliciano	Paint	7 Alpine Dr								
5241749	21576	0		TRUE	FALSE	5/24/2024	5:51 PM	Danny Feliciano	Paint	7 Alpine Dr								
5241749	21577	-0.7	Negative	FALSE	TRUE	5/24/2024	5:52 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door		Wood	A	
5241749	21578	0	Negative	FALSE	FALSE	5/24/2024	5:53 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door	Casing	Wood	A	
5241749	21579	-0.4	Negative	FALSE	TRUE	5/24/2024	5:53 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Window	Casing	Wood	A	1
5241749	21580	-0.6	Negative	FALSE	TRUE	5/24/2024	5:54 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Window	Sill	Wood	A	1
5241749	21581	-0.6	Negative	FALSE	TRUE	5/24/2024	5:54 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Window	Seat	Wood	A	Lower
5241749	21582	0	Negative	FALSE	FALSE	5/24/2024	5:55 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Baseboard	Wood	A	
5241749	21583	-0.7	Negative	FALSE	TRUE	5/24/2024	5:55 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Closet	Bi-Fold Door	Wood	C	
5241749	21584	-0.7	Negative	FALSE	TRUE	5/24/2024	5:56 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Closet	Door Casing	Wood	C	
5241749	21585	0	Negative	FALSE	TRUE	5/24/2024	5:57 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Window	Casing	Wood	A	
5241749	21586	-0.5	Negative	FALSE	TRUE	5/24/2024	5:57 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Window	Sill	Wood	A	
5241749	21587	0	Negative	FALSE	FALSE	5/24/2024	5:58 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door		Wood	B	
5241749	21588	-0.4	Negative	FALSE	TRUE	5/24/2024	5:58 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door	Casing	Wood	B	
5241749	21589	-0.7	Negative	FALSE	TRUE	5/24/2024	5:58 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door	Jamb	Wood	B	
5241749	21590	-0.7	Negative	FALSE	TRUE	5/24/2024	5:59 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door	Casing	Wood	C	
5241749	21591	-0.7	Negative	FALSE	TRUE	5/24/2024	5:59 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Door	Jamb	Wood	C	
5241749	21592	-0.1	Negative	FALSE	FALSE	5/24/2024	6:00 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Beam	Wood		
5241749	21593	0.1	Negative	FALSE	FALSE	5/24/2024	6:01 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Ceiling	Plaster		
5241749	21594	0	Negative	FALSE	FALSE	5/24/2024	6:01 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Wall	Drywall	A	
5241749	21595	-0.4	Negative	FALSE	TRUE	5/24/2024	6:02 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Wall	Drywall	D	
5241749	21596	-0.6	Negative	FALSE	TRUE	5/24/2024	6:02 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Wall	Drywall	C	
5241749	21597	-0.8	Negative	FALSE	TRUE	5/24/2024	6:02 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Kitchen/Living/Dining	Room	Wall	Drywall	B	
5241749	21598	0.3	Negative	FALSE	FALSE	5/24/2024	6:03 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Room	Wall	Drywall	B	
5241749	21599	-0.5	Negative	FALSE	TRUE	5/24/2024	6:03 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Room	Wall	Drywall	A	
5241749	21600	-0.1	Negative	FALSE	FALSE	5/24/2024	6:04 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Room	Wall	Drywall	D	
5241749	21601	0.3	Negative	FALSE	FALSE	5/24/2024	6:04 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Room	Ceiling	Plaster		
5241749	21602	-0.7	Negative	FALSE	TRUE	5/24/2024	6:05 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Door	Casing	Wood	D	
5241749	21603	-0.8	Negative	FALSE	TRUE	5/24/2024	6:08 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Door	Jamb	Wood	D	
5241749	21604	-0.8	Negative	FALSE	TRUE	5/24/2024	6:08 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Door	Jamb	Wood	D	2
5241749	21605	-0.1	Negative	FALSE	FALSE	5/24/2024	6:09 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Door	---	Wood	D	
5241749	21606	-0.5	Negative	FALSE	TRUE	5/24/2024	6:09 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Window	Casing	Wood	A	
5241749	21607	-0.6	Negative	FALSE	TRUE	5/24/2024	6:10 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Window	Sill	Wood	A	
5241749	21608	-0.4	Negative	FALSE	TRUE	5/24/2024	6:10 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bathroom	Door	Casing	Wood	A	
5241749	21609	-0.6	Negative	FALSE	TRUE	5/24/2024	6:11 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bedroom	Closet	Bi-Fold Door	Wood	C	
5241749	21610	-0.6	Negative	FALSE	TRUE	5/24/2024	6:11 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bedroom	Closet	Door Casing	Wood	C	
5241749	21611	-0.7	Negative	FALSE	TRUE	5/24/2024	6:12 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bedroom	Closet	Door Jamb	Wood	C	
5241749	21612	-0.9	Negative	FALSE	TRUE	5/24/2024	6:12 PM	Danny Feliciano	Paint	7 Alpine Dr	Unit	3	Bedroom	Closet	Shelf Support	Wood	C	

Company LEW Corporation
XRF Make Heuresis
Model Pb200i
Serial Num. 2128

Lead concentration units: mg/cm2

Total Readings: 45 Total Positives 0

Action Level 1

Mode Action Level

Analytic Mode Paint

Actionables

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
No Actionables																		