

Company LEW Corporation  
 XRF Make Heuresis  
 Model Pb200i  
 Serial Num. 2819

Lead concentration units: mg/cm2  
 Total Readings: 160  
 Action Level 1  
 Mode Action Level  
 Analytic Mode Paint

**All Readings**

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause	
6171114	47392	1.1		TRUE	FALSE	6/17/2024	11:15 AM	Yerani Heredia	Paint	95 Glen Ave.											
6171114	47393	1		TRUE	FALSE	6/17/2024	11:16 AM	Yerani Heredia	Paint	95 Glen Ave.											
6171114	47394	1		TRUE	FALSE	6/17/2024	11:16 AM	Yerani Heredia	Paint	95 Glen Ave.											
6171114	47395	0		TRUE	FALSE	6/17/2024	11:17 AM	Yerani Heredia	Paint	95 Glen Ave.											
6171114	47396	0		TRUE	FALSE	6/17/2024	11:17 AM	Yerani Heredia	Paint	95 Glen Ave.											
6171114	47397	0		TRUE	FALSE	6/17/2024	11:18 AM	Yerani Heredia	Paint	95 Glen Ave.											
6171114	47398	0.1	Negative	FALSE	FALSE	6/17/2024	11:18 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Door	---	Wood	A	1	Intact		
6171114	47399	-0.1	Negative	FALSE	FALSE	6/17/2024	11:19 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Door	Jamb	Wood	A	1	Intact		
6171114	47400	0.1	Negative	FALSE	FALSE	6/17/2024	11:19 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Door	Casing	Wood	A	1	Intact		
6171114	47401	0.1	Negative	FALSE	FALSE	6/17/2024	11:20 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Window	Casing	Wood	A	1	Intact		
6171114	47402	-0.1	Negative	FALSE	FALSE	6/17/2024	11:20 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Window	Sill	Wood	A	1	Intact		
6171114	47403	-0.1	Negative	FALSE	FALSE	6/17/2024	11:21 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Window	Apron	Wood	A	1	Intact		
6171114	47404	0	Negative	FALSE	FALSE	6/17/2024	11:21 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Room	Baseboard	Wood	A	1	Intact		
6171114	47405	0.1	Negative	FALSE	FALSE	6/17/2024	11:22 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Room	Wall	Plaster	A	1	Intact		
6171114	47406	0.1	Negative	FALSE	FALSE	6/17/2024	11:22 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Room	Wall	Plaster	B	1	Intact		
6171114	47407	0	Negative	FALSE	FALSE	6/17/2024	11:23 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Room	Wall	Plaster	C	1	Intact		
6171114	47408	0.1	Negative	FALSE	FALSE	6/17/2024	11:23 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Room	Wall	Plaster	D	1	Intact		
6171114	47409	0	Negative	FALSE	FALSE	6/17/2024	11:24 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Room	Ceiling	Drywall	D	1	Intact		
6171114	47410	0.2	Negative	FALSE	FALSE	6/17/2024	11:24 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Risers	Wood	B	1	Intact		
6171114	47411	0.2	Negative	FALSE	FALSE	6/17/2024	11:25 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Stringer	Wood	B	1	Intact		
6171114	47412	0	Negative	FALSE	FALSE	6/17/2024	11:25 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Newel Post	Wood	B	1	Intact		
6171114	47413	0	Negative	FALSE	FALSE	6/17/2024	11:26 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Railing	Wood	B	1	Intact		
6171114	47414	0	Negative	FALSE	FALSE	6/17/2024	11:26 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Balusters	Wood	B	1	Intact		
6171114	47415	0.1	Negative	FALSE	FALSE	6/17/2024	11:27 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Underside	Wood	B	1	Intact		
6171114	47416	-0.1	Negative	FALSE	FALSE	6/17/2024	11:27 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Door	Casing	Wood	B	1	Intact		
6171114	47417	0.2	Negative	FALSE	FALSE	6/17/2024	11:28 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Room	Wall	Plaster	A	1	Intact		
6171114	47418	0	Negative	FALSE	FALSE	6/17/2024	11:29 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Room	Wall	Plaster	B	1	Intact		
6171114	47419	0.1	Negative	FALSE	FALSE	6/17/2024	11:29 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Room	Wall	Plaster	C	1	Intact		
6171114	47420	0.1	Negative	FALSE	FALSE	6/17/2024	11:30 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Room	Wall	Plaster	D	1	Intact		
6171114	47421	0	Negative	FALSE	FALSE	6/17/2024	11:31 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Window	Casing	Wood	A	1	Intact		
6171114	47422	0.2	Negative	FALSE	FALSE	6/17/2024	11:32 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Window	Sill	Wood	A	1	Intact		
6171114	47423	-0.1	Negative	FALSE	FALSE	6/17/2024	11:32 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Window	Apron	Wood	A	1	Intact		
6171114	47424	-0.1	Negative	FALSE	FALSE	6/17/2024	11:33 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Living Room	Room	Baseboard	Wood	A	1	Intact		
6171114	47425	0	Negative	FALSE	FALSE	6/17/2024	11:34 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Room	Baseboard	Wood	A	1	Intact		
6171114	47426	0.2	Negative	FALSE	FALSE	6/17/2024	11:34 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Room	Wall	Plaster	A	1	Intact		
6171114	47427	0.1	Negative	FALSE	FALSE	6/17/2024	11:35 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Room	Wall	Plaster	B	1	Intact		
6171114	47428	0.1	Negative	FALSE	FALSE	6/17/2024	11:35 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Room	Wall	Plaster	C	1	Intact		
6171114	47429	0.1	Negative	FALSE	FALSE	6/17/2024	11:36 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Room	Wall	Plaster	D	1	Intact		
6171114	47430	0	Negative	FALSE	FALSE	6/17/2024	11:36 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Window	Casing	Wood	D	1	Intact		
6171114	47431	0	Negative	FALSE	FALSE	6/17/2024	11:37 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Window	Sill	Wood	D	1	Intact		
6171114	47432	-0.1	Negative	FALSE	FALSE	6/17/2024	11:38 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Dining Room	Window	Apron	Wood	D	1	Intact		
6171114	47433	0.1	Negative	FALSE	FALSE	6/17/2024	11:39 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Door	---	Wood	D	1	Intact		
6171114	47434	0	Negative	FALSE	FALSE	6/17/2024	11:39 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Door	Jamb	Wood	D	1	Intact		
6171114	47435	0	Negative	FALSE	FALSE	6/17/2024	11:40 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Door	Casing	Wood	D	1	Intact		
6171114	47436	0.1	Negative	FALSE	FALSE	6/17/2024	11:41 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Door	Casing	Wood	A	1	Intact		
6171114	47437	0.3	Negative	FALSE	FALSE	6/17/2024	11:41 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Room	Wall	Plaster	A	1	Intact		

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
6171114	47438	0.1	Negative	FALSE	FALSE	6/17/2024	11:42 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Room	Wall	Plaster	B	1	Intact	
6171114	47439	0.1	Negative	FALSE	FALSE	6/17/2024	11:42 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Room	Wall	Plaster	C	1	Intact	
6171114	47440	0.2	Negative	FALSE	FALSE	6/17/2024	11:43 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Room	Wall	Plaster	D	1	Intact	
6171114	47441	-0.1	Negative	FALSE	FALSE	6/17/2024	11:43 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Room	Baseboard	Wood	D	1	Intact	
6171114	47442	0	Negative	FALSE	FALSE	6/17/2024	11:44 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Window	Casing	Wood	B	1	Intact	
6171114	47443	-0.1	Negative	FALSE	FALSE	6/17/2024	11:45 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Kitchen	Window	Sill	Wood	B	1	Intact	
6171114	47444	0.1	Negative	FALSE	FALSE	6/17/2024	11:46 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Door	---	Metal	C	1	Intact	
6171114	47445	0.1	Negative	FALSE	FALSE	6/17/2024	11:46 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Door	Jamb	Wood	C	1	Intact	
6171114	47446	0.2	Negative	FALSE	FALSE	6/17/2024	11:47 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Door	Casing	Wood	C	1	Intact	
6171114	47447	13.7	Positive	FALSE	FALSE	6/17/2024	11:47 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Window	Casing	Wood	C	1	Intact	
6171114	47448	11.9	Positive	FALSE	FALSE	6/17/2024	11:48 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Window	Sill	Wood	C	1	Intact	
6171114	47449	12.5	Positive	FALSE	FALSE	6/17/2024	11:49 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Window	Apron	Wood	C	1	Intact	
6171114	47450	11.8	Positive	FALSE	FALSE	6/17/2024	11:50 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Shelf	---	Wood	C	1	Intact	
6171114	47451	16	Positive	FALSE	FALSE	6/17/2024	11:50 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Wall	Wood	C	1	Intact	
6171114	47452	0.1	Negative	FALSE	FALSE	6/17/2024	11:51 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Wall	Wood	A	1	Intact	
6171114	47453	8.6	Positive	FALSE	FALSE	6/17/2024	11:52 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Stair	Treads	Wood	D	1	Intact	
6171114	47454	11	Positive	FALSE	FALSE	6/17/2024	11:56 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Wall	Wood	D	1	Intact	
6171114	47455	0.2	Negative	FALSE	FALSE	6/17/2024	11:56 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Wall	Concrete	D	1	Intact	
6171114	47456	0.1	Negative	FALSE	FALSE	6/17/2024	11:57 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Door	---	Wood	C	1	Intact	
6171114	47457	-0.1	Negative	FALSE	FALSE	6/17/2024	11:58 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Door	Casing	Wood	C	1	Intact	
6171114	47458	0.1	Negative	FALSE	FALSE	6/17/2024	11:58 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Room	Wall	Plaster	A	1	Intact	
6171114	47459	0	Negative	FALSE	FALSE	6/17/2024	11:59 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Room	Wall	Plaster	B	1	Intact	
6171114	47460	0.1	Negative	FALSE	FALSE	6/17/2024	11:59 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Room	Wall	Plaster	C	1	Intact	
6171114	47461	0.1	Negative	FALSE	FALSE	6/17/2024	12:00 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Room	Wall	Plaster	D	1	Intact	
6171114	47462	0	Negative	FALSE	FALSE	6/17/2024	12:02 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	1/2 Bathroom	Room	Ceiling	Drywall	D	1	Intact	
6171114	47463	0.1	Negative	FALSE	FALSE	6/17/2024	12:03 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Foyer	Stair	Wall	Plaster	C	1	Intact	
6171114	47464	0.2	Negative	FALSE	FALSE	6/17/2024	12:04 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Room	Wall	Plaster	A	1	Intact	
6171114	47465	0	Negative	FALSE	FALSE	6/17/2024	12:04 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Room	Wall	Plaster	B	1	Intact	
6171114	47466	0.3	Negative	FALSE	FALSE	6/17/2024	12:05 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Room	Wall	Plaster	C	1	Intact	
6171114	47467	0.2	Negative	FALSE	FALSE	6/17/2024	12:05 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Room	Wall	Plaster	D	1	Intact	
6171114	47468	0.1	Negative	FALSE	FALSE	6/17/2024	12:06 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Room	Baseboard	Wood	D	1	Intact	
6171114	47469	0.2	Negative	FALSE	FALSE	6/17/2024	12:06 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Door	---	Wood	D	1	Intact	
6171114	47470	-0.1	Negative	FALSE	FALSE	6/17/2024	12:07 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Door	Jamb	Wood	D	1	Intact	
6171114	47471	-0.1	Negative	FALSE	FALSE	6/17/2024	12:07 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Door	Casing	Wood	D	1	Intact	
6171114	47472	-0.1	Negative	FALSE	FALSE	6/17/2024	12:08 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Door	---	Wood	D	1	Intact	
6171114	47473	0.1	Negative	FALSE	FALSE	6/17/2024	12:08 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Door	Jamb	Wood	D	1	Intact	
6171114	47474	0	Negative	FALSE	FALSE	6/17/2024	12:09 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Door	Casing	Wood	D	1	Intact	
6171114	47475	0.2	Negative	FALSE	FALSE	6/17/2024	12:09 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Room	Wall	Plaster	A	1	Intact	
6171114	47476	0.1	Negative	FALSE	FALSE	6/17/2024	12:10 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Room	Wall	Plaster	B	1	Intact	
6171114	47477	0.2	Negative	FALSE	FALSE	6/17/2024	12:10 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Room	Wall	Plaster	C	1	Intact	
6171114	47478	-0.1	Negative	FALSE	FALSE	6/17/2024	12:11 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Room	Wall	Plaster	D	1	Intact	
6171114	47479	0	Negative	FALSE	FALSE	6/17/2024	12:11 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Room	Baseboard	Wood	D	1	Intact	
6171114	47480	0	Negative	FALSE	FALSE	6/17/2024	12:12 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Room	Ceiling	Drywall	D	1	Intact	
6171114	47481	0	Negative	FALSE	FALSE	6/17/2024	12:13 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Window	Casing	Drywall	B	1	Intact	
6171114	47482	-0.1	Negative	FALSE	FALSE	6/17/2024	12:13 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Window	Sill	Wood	B	1	Intact	
6171114	47483	0	Negative	FALSE	FALSE	6/17/2024	12:14 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bathroom	Window	Apron	Wood	B	1	Intact	
6171114	47484	0.1	Negative	FALSE	FALSE	6/17/2024	12:15 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Door	---	Wood	B	1	Intact	
6171114	47485	0	Negative	FALSE	FALSE	6/17/2024	12:15 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Door	Jamb	Wood	B	1	Intact	
6171114	47486	0	Negative	FALSE	FALSE	6/17/2024	12:16 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Door	Casing	Wood	B	1	Intact	
6171114	47487	0	Negative	FALSE	FALSE	6/17/2024	12:16 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Room	Wall	Plaster	B	1	Intact	
6171114	47488	0.2	Negative	FALSE	FALSE	6/17/2024	12:17 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Room	Wall	Plaster	B	1	Intact	
6171114	47489	0.1	Negative	FALSE	FALSE	6/17/2024	12:17 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Room	Wall	Plaster	C	1	Intact	
6171114	47490	0	Negative	FALSE	FALSE	6/17/2024	12:18 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Room	Wall	Plaster	D	1	Intact	
6171114	47491	0	Negative	FALSE	FALSE	6/17/2024	12:18 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Room	Baseboard	Wood	D	1	Intact	
6171114	47492	0	Negative	FALSE	FALSE	6/17/2024	12:19 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Window	Casing	Wood	A	1	Intact	
6171114	47493	-0.1	Negative	FALSE	FALSE	6/17/2024	12:20 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Window	Sill	Wood	A	1	Intact	
6171114	47494	0	Negative	FALSE	FALSE	6/17/2024	12:20 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Closet	Door	Wood	D	1	Intact	
6171114	47495	0.1	Negative	FALSE	FALSE	6/17/2024	12:21 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Closet	Door Jamb	Wood	D	1	Intact	



Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
6171114	47496	0	Negative	FALSE	FALSE	6/17/2024	12:22 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Closet	Door Casing	Wood	D	1	Intact	
6171114	47497	-0.2	Negative	FALSE	FALSE	6/17/2024	12:22 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Closet	Shelf	Wood	D	1	Intact	
6171114	47498	-0.1	Negative	FALSE	FALSE	6/17/2024	12:23 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Closet	Shelf Support	Wood	D	1	Intact	
6171114	47499	0.6	Negative	FALSE	FALSE	6/17/2024	12:23 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Closet	Wall	Plaster	D	1	Intact	
6171114	47500	0.1	Negative	FALSE	FALSE	6/17/2024	12:25 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Room	Ceiling	Drywall	D	1	Intact	
6171114	47501	0.1	Negative	FALSE	FALSE	6/17/2024	12:26 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Door	---	Wood	C	1	Intact	
6171114	47502	0	Negative	FALSE	FALSE	6/17/2024	12:26 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Door	Jamb	Wood	C	1	Intact	
6171114	47503	-0.1	Negative	FALSE	FALSE	6/17/2024	12:27 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 3	Door	Casing	Wood	C	1	Intact	
6171114	47504	0.2	Negative	FALSE	FALSE	6/17/2024	12:28 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Door	---	Wood	C	1	Intact	
6171114	47505	0	Negative	FALSE	FALSE	6/17/2024	12:28 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Door	Jamb	Wood	C	1	Intact	
6171114	47506	0.1	Negative	FALSE	FALSE	6/17/2024	12:29 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Door	Casing	Wood	C	1	Intact	
6171114	47507	-0.4	Negative	FALSE	FALSE	6/17/2024	12:29 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Room	Wall	Plaster	A	1	Intact	
6171114	47508	0	Negative	FALSE	FALSE	6/17/2024	12:30 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Room	Wall	Plaster	B	1	Intact	
6171114	47509	0.2	Negative	FALSE	FALSE	6/17/2024	12:30 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Room	Wall	Plaster	C	1	Intact	
6171114	47510	0	Negative	FALSE	FALSE	6/17/2024	12:31 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Room	Wall	Plaster	D	1	Intact	
6171114	47511	-0.2	Negative	FALSE	FALSE	6/17/2024	12:32 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Room	Baseboard	Wood	D	1	Intact	
6171114	47512	-0.1	Negative	FALSE	FALSE	6/17/2024	12:32 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Door	Wood	D	1	Intact	
6171114	47513	0.1	Negative	FALSE	FALSE	6/17/2024	12:33 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Door Jamb	Wood	D	1	Intact	
6171114	47514	0.1	Negative	FALSE	FALSE	6/17/2024	12:33 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Door Casing	Wood	D	1	Intact	
6171114	47515	0	Negative	FALSE	FALSE	6/17/2024	12:34 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Wall	Plaster	D	1	Intact	
6171114	47516	0.1	Negative	FALSE	FALSE	6/17/2024	12:35 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Baseboard	Wood	D	1	Intact	
6171114	47517	0.2	Negative	FALSE	FALSE	6/17/2024	12:36 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Wall	Plaster	D	1	Intact	
6171114	47518	-0.3	Negative	FALSE	FALSE	6/17/2024	12:37 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Closet	Shelf Support	Wood	D	1	Intact	
6171114	47519	0.1	Negative	FALSE	FALSE	6/17/2024	12:38 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Window	Casing	Wood	C	1	Intact	
6171114	47520	0.1	Negative	FALSE	FALSE	6/17/2024	12:38 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Window	Sill	Wood	C	1	Intact	
6171114	47521	-0.1	Negative	FALSE	FALSE	6/17/2024	12:39 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Window	Apron	Wood	C	1	Intact	
6171114	47522	0.2	Negative	FALSE	FALSE	6/17/2024	12:40 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Door	---	Wood	C	1	Intact	
6171114	47523	0.1	Negative	FALSE	FALSE	6/17/2024	12:40 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Door	Jamb	Wood	C	1	Intact	
6171114	47524	-0.1	Negative	FALSE	FALSE	6/17/2024	12:41 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Door	Casing	Wood	C	1	Intact	
6171114	47525	0.1	Negative	FALSE	FALSE	6/17/2024	12:41 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Window	Casing	Wood	A	1	Intact	
6171114	47526	0.1	Negative	FALSE	FALSE	6/17/2024	12:42 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Window	Sill	Wood	A	1	Intact	
6171114	47527	0.1	Negative	FALSE	FALSE	6/17/2024	12:42 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Window	Apron	Wood	A	1	Intact	
6171114	47528	0.1	Negative	FALSE	FALSE	6/17/2024	12:43 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Room	Wall	Plaster	A	1	Intact	
6171114	47529	0.1	Negative	FALSE	FALSE	6/17/2024	12:43 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Room	Wall	Plaster	B	1	Intact	
6171114	47530	-0.2	Negative	FALSE	FALSE	6/17/2024	12:44 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Room	Wall	Plaster	C	1	Intact	
6171114	47531	0.1	Negative	FALSE	FALSE	6/17/2024	12:44 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Room	Wall	Plaster	D	1	Intact	
6171114	47532	0.1	Negative	FALSE	FALSE	6/17/2024	12:45 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Room	Baseboard	Wood	D	1	Intact	
6171114	47533	0.1	Negative	FALSE	FALSE	6/17/2024	12:46 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Door	---	Wood	B	1	Intact	
6171114	47534	0.1	Negative	FALSE	FALSE	6/17/2024	12:46 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Door	Jamb	Wood	B	1	Intact	
6171114	47535	0	Negative	FALSE	FALSE	6/17/2024	12:46 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Door	Casing	Wood	B	1	Intact	
6171114	47536	0.2	Negative	FALSE	FALSE	6/17/2024	12:47 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Room	Wall	Plaster	A	1	Intact	
6171114	47537	0	Negative	FALSE	FALSE	6/17/2024	12:48 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Room	Wall	Plaster	B	1	Intact	
6171114	47538	0.1	Negative	FALSE	FALSE	6/17/2024	12:48 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Room	Wall	Plaster	C	1	Intact	
6171114	47539	0.1	Negative	FALSE	FALSE	6/17/2024	12:49 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Room	Wall	Plaster	D	1	Intact	
6171114	47540	-0.1	Negative	FALSE	FALSE	6/17/2024	12:50 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Room	Baseboard	Wood	D	1	Intact	
6171114	47541	0.1	Negative	FALSE	FALSE	6/17/2024	12:50 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Window	Casing	Wood	C	1	Intact	
6171114	47542	0.1	Negative	FALSE	FALSE	6/17/2024	12:51 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Window	Sill	Wood	C	1	Intact	
6171114	47543	0	Negative	FALSE	FALSE	6/17/2024	12:51 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Door	Wood	B	1	Intact	
6171114	47544	-0.1	Negative	FALSE	FALSE	6/17/2024	12:52 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Door Jamb	Wood	B	1	Intact	
6171114	47545	-0.1	Negative	FALSE	FALSE	6/17/2024	12:52 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Door Casing	Wood	B	1	Intact	
6171114	47546	0	Negative	FALSE	FALSE	6/17/2024	12:53 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Shelf	Wood	B	1	Intact	
6171114	47547	0.2	Negative	FALSE	FALSE	6/17/2024	12:53 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Shelf Support	Wood	B	1	Intact	
6171114	47548	0.1	Negative	FALSE	FALSE	6/17/2024	12:54 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Shelf	Wood	B	1	Intact	
6171114	47549	-0.5	Negative	FALSE	FALSE	6/17/2024	12:55 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Closet	Wall	Plaster	B	1	Intact	
6171114	47550	0.1	Negative	FALSE	FALSE	6/17/2024	12:56 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 2	Room	Ceiling	Wood	B	1	Intact	
6171114	47551	-0.1	Negative	FALSE	FALSE	6/17/2024	12:57 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	2nd Floor Hallway	Room	Ceiling	Wood	B	1	Intact	
6171114	47552	0.1	Negative	FALSE	FALSE	6/17/2024	12:58 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 1	Room	Ceiling	Wood	B	1	Intact	
6171114	47553	0.1	Negative	FALSE	FALSE	6/17/2024	1:00 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Bedroom 4	Room	Ceiling	Wood	B	1	Intact	



Company LEW Corporation  
 XRF Make Heuresis  
 Model Pb200i  
 Serial Num. 2819

Lead concentration units: mg/cm2

Total Readings: 160 Total Positives 8

Action Level 1

Mode Action Level

Analytic Mode Paint

**Actionables**

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
6171114	47447	13.7	Positive	FALSE	FALSE	6/17/2024	11:47 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Window	Casing	Wood	C	1	Intact	
6171114	47448	11.9	Positive	FALSE	FALSE	6/17/2024	11:48 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Window	Sill	Wood	C	1	Intact	
6171114	47449	12.5	Positive	FALSE	FALSE	6/17/2024	11:49 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Window	Apron	Wood	C	1	Intact	
6171114	47450	11.8	Positive	FALSE	FALSE	6/17/2024	11:50 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Shelf	---	Wood	C	1	Intact	
6171114	47451	16	Positive	FALSE	FALSE	6/17/2024	11:50 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Wall	Wood	C	1	Intact	
6171114	47453	8.6	Positive	FALSE	FALSE	6/17/2024	11:52 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Stair	Treads	Wood	D	1	Intact	
6171114	47454	11	Positive	FALSE	FALSE	6/17/2024	11:56 AM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Wall	Wood	D	1	Intact	
6171114	47557	15.7	Positive	FALSE	FALSE	6/17/2024	1:05 PM	Yerani Heredia	Paint	95 Glen Ave.	Unit	1	Rear Entry	Room	Ceiling	Wood	B	1	Intact	

Company LEW Corporation  
XRF Make Heuresis  
Model Pb200i  
Serial Num. 2819

Lead concentration units: mg/cm2

Total Readings: 160 Total Hazards 0

Action Level 1

Mode Action Level

Analytic Mode Paint

### Hazards

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location	Condition	Cause
No Hazards																				