

Company LEW Corporation  
 XRF Make Heuresis  
 Model Pb200i  
 Serial Num. 2096

Lead concentration units: mg/cm2  
 Total Readings: 76  
 Action Level 1  
 Mode Action Level  
 Analytic Mode Paint

All Readings

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
11210921	3748	0.1	Negative	FALSE	FALSE	11/21/2024	11:04 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Room	Wall	Drywall	A	
11210921	3749	0	Negative	FALSE	FALSE	11/21/2024	11:04 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Room	Wall	Drywall	B	
11210921	3750	0	Negative	FALSE	FALSE	11/21/2024	11:05 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Room	Wall	Drywall	C	
11210921	3751	0.1	Negative	FALSE	FALSE	11/21/2024	11:06 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Room	Wall	Drywall	D	
11210921	3752	-0.1	Negative	FALSE	FALSE	11/21/2024	11:06 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Room	Baseboard	Wood	D	
11210921	3753	-0.1	Negative	FALSE	FALSE	11/21/2024	11:07 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Window	Casing	Wood	D	
11210921	3754	0	Negative	FALSE	FALSE	11/21/2024	11:08 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Room	Ceiling	Drywall		
11210921	3755	0	Negative	FALSE	FALSE	11/21/2024	11:09 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Closet	Door	Wood	D	
11210921	3756	-0.1	Negative	FALSE	FALSE	11/21/2024	11:10 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Closet	Door Casing	Wood	D	
11210921	3757	0.6	Negative	FALSE	FALSE	11/21/2024	11:11 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Closet	Door Jamb	Wood	D	
11210921	3758	0.3	Negative	FALSE	FALSE	11/21/2024	11:11 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Closet	Shelf Support	Wood	D	
11210921	3759	0.4	Negative	FALSE	FALSE	11/21/2024	11:13 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Door		Wood	B	1
11210921	3760	0	Negative	FALSE	FALSE	11/21/2024	11:14 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Door	Jamb	Wood	B	1
11210921	3761	0	Negative	FALSE	FALSE	11/21/2024	11:15 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Access Panel	Door	Wood		1
11210921	3762	-0.1	Negative	FALSE	FALSE	11/21/2024	11:16 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Living Room/Kitchen	Access Panel	Casing	Wood		
11210921	3763	0.1	Negative	FALSE	FALSE	11/21/2024	11:17 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Door		Wood	D	
11210921	3764	0	Negative	FALSE	FALSE	11/21/2024	11:17 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Door	Casing	Wood	D	
11210921	3765	-0.2	Negative	FALSE	FALSE	11/21/2024	11:20 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Room	Baseboard	Wood	D	
11210921	3766	0	Negative	FALSE	FALSE	11/21/2024	11:21 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Room	Wall	Drywall	D	
11210921	3767	0	Negative	FALSE	FALSE	11/21/2024	11:22 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Room	Wall	Drywall	C	
11210921	3768	0.1	Negative	FALSE	FALSE	11/21/2024	11:22 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Room	Wall	Drywall	B	
11210921	3769	0.1	Negative	FALSE	FALSE	11/21/2024	11:23 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Room	Wall	Drywall	A	
11210921	3770	0	Negative	FALSE	FALSE	11/21/2024	11:23 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Room	Ceiling	Drywall		
11210921	3771	-0.1	Negative	FALSE	FALSE	11/21/2024	11:24 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Window	Casing	Wood	B	
11210921	3772	0	Negative	FALSE	FALSE	11/21/2024	11:24 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Closet	Door	Wood	A	
11210921	3773	0.7	Negative	FALSE	FALSE	11/21/2024	11:25 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 1	Closet	Door Jamb	Wood	A	
11210921	3774	0.5	Negative	FALSE	FALSE	11/21/2024	11:27 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Closet	Door Jamb	Wood	C	1
11210921	3775	-0.1	Negative	FALSE	FALSE	11/21/2024	11:28 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Closet	Door Jamb	Wood	C	2
11210921	3776	0.1	Negative	FALSE	FALSE	11/21/2024	11:28 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Closet	Door	Wood	C	2
11210921	3777	0	Negative	FALSE	FALSE	11/21/2024	11:29 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Closet	Door	Wood	C	1
11210921	3778	-0.1	Negative	FALSE	FALSE	11/21/2024	11:30 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Window	Casing	Wood	B	1
11210921	3779	-0.1	Negative	FALSE	FALSE	11/21/2024	11:30 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Room	Baseboard	Wood	B	1
11210921	3780	0.2	Negative	FALSE	FALSE	11/21/2024	11:31 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Room	Wall	Drywall	B	1
11210921	3781	0.1	Negative	FALSE	FALSE	11/21/2024	11:31 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Room	Wall	Drywall	C	
11210921	3782	0.1	Negative	FALSE	FALSE	11/21/2024	11:32 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Room	Wall	Drywall	D	
11210921	3783	0.1	Negative	FALSE	FALSE	11/21/2024	11:32 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Room	Wall	Drywall	A	
11210921	3784	0.1	Negative	FALSE	FALSE	11/21/2024	11:33 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Room	Ceiling	Drywall		
11210921	3785	0.1	Negative	FALSE	FALSE	11/21/2024	11:33 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Door		Wood	D	
11210921	3786	0.1	Negative	FALSE	FALSE	11/21/2024	11:34 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Bedroom 2	Door	Jamb	Wood	D	
11210921	3787	0	Negative	FALSE	FALSE	11/21/2024	11:35 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Door	Jamb	Wood	D	
11210921	3788	0.1	Negative	FALSE	FALSE	11/21/2024	11:35 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Room	Ceiling	Drywall		
11210921	3789	0	Negative	FALSE	FALSE	11/21/2024	11:36 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Room	Wall	Drywall	A	
11210921	3790	0.1	Negative	FALSE	FALSE	11/21/2024	11:36 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Room	Wall	Drywall	D	
11210921	3791	0	Negative	FALSE	FALSE	11/21/2024	11:37 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Room	Wall	Drywall	C	
11210921	3792	0.1	Negative	FALSE	FALSE	11/21/2024	11:37 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Room	Wall	Drywall	B	
11210921	3793	0	Negative	FALSE	FALSE	11/21/2024	11:39 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Window	Casing	Wood	C	1
11210921	3794	-0.1	Negative	FALSE	FALSE	11/21/2024	11:39 AM	Danny Feliciano	Paint	1123-25 Putnam Ave	Unit	2	Storage Room	Room	Baseboard	Wood	C	



Company LEW Corporation  
XRF Make Heuresis  
Model Pb200i  
Serial Num. 2096

Lead concentration units: mg/cm2

Total Readings: 76 Total Positives 0

Action Level 1

Mode Action Level

Analytic Mode Paint

### Actionables

Job Id	Reading #	Concentration	Result	Calibration	RTA Present	Date	Time	User	Analytic Mode	Site Address	Area	Unit #	Room	Structure	Member	Substrate	Wall	Location
No Actionables																		